



# Certificate of Compliance

This certificate is issued for the following:

**Non-Gasketed Pipe Fittings for Use with Aboveground Sprinkler Systems**

**Ductile Iron Non-Gasketed Fittings Manufactured to  
ASME B16.3 and ASME B 16.14 Specifications**

**with a Rated Working Pressure of 500 psi (3450 kPa)**

**Prepared for:**

PT Tri Sinar Purnama  
Jl Moch Ichsan RT 01/ RW 01 Kelurahan Wates  
Kecamatan Ngaliyan  
Semarang 50188  
Indonesia

**Manufactured at:**

PT Laju Sinergi Metalindo  
Tugu Wijaya Kusuma IV, No. 24 Kelurahan Tugu,  
Kecamatan, Randugarut  
Semarang 50153, Jawa  
Tengah, Indonesia

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”, dated November, 2007

Approval Identification: PR453243

Approval Granted: December 11, 2019

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D. B. Fuller', written over a horizontal line.

David B. Fuller  
VP - Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*